



Product Service

# CERTIFICATE

No. Z1A 15 06 91450 001

**Holder of Certificate:** Normagrup Technology, S.A.  
 Parque Tecnológico de Asturias, Parcela 10  
 33428 Llanera  
 SPAIN

**Certification Mark:**



**Product:** Emergency lighting appliances

**Tested according to:** EN 60598-1:2008/A11:2009  
 EN 60598-2-22:1998/A2:2008  
 EN 62471:2008  
 EN 62493:2010  
 AfPS GS 2014:01 PAK

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

**Test report no.:** 713058597-000

**Valid until:** 2020-05-31



**Date,** 2015-06-02

*Thomas Kokorsch*  
 (Thomas Kokorsch)

Page 1 of 2



Product Service

**CERTIFICATE**  
**No. Z1A 15 06 91450 001**

**Model(s):** **DUNNA**

**Brand Name:** **DUNNA; Normagrup**

**Parameters:**

Rated voltage:	230 V~
Rated frequency:	50 Hz
Rated Power:	D-30L(0,4W) D-60L(0,4W) D-100L(1W) D-150L(1W) D-200L(1W) D-300L(1W) D-400L(1W) D-500L(2,2W) D-600L(2,2W) D2-200L(2,2W) D2-400L(2,2W) D3-60L(1W) D3-200L(2,2W)
Protection class:	II
Degree of protection:	IP42

**Factory(ies):** 91450