

**- Declaration of Conformity -**  
**CE Marking**

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A that the surface mounted emergency lights mentioned below comply with all related standards:

COMERCIAL BRAND: **ARQUE**

References:

Q-100L, Q-200L, Q-300L, Q3-100L, QA-100L, QA-200L, QA-300L, QAL-150Li, QAL-250Li, QAL3-250Li, QE-300L, QIDL-150Li, QIDL-250Li, QIDL3-250Li, QL-100, QL-200, QL-300, QL3-100, QS-100L, QS-200L, QS-300L, QS3-100L, QSA-100L, QSA-200L, QSA-300L, QSAL-150Li, QSAL-250Li, QSAL3-250Li, QSE-100L, QSEIDL-250Li, QSIDL-150Li, QSIDL-250Li, QSIDL3-250Li, QSL-100, QSL-200, QSL-300, QSL3-100, QV-100L, QV-200L, QV-300L, QV3-100L, QVA-100L, QVA-200L, QVA-300L, QVAL-150Li, QVAL-250Li, QVAL3-250L, QVEAL3-250Li, QVIDL-150Li, QVIDL-250Li, QVIDL3-250Li, QVL-100, QVL-200, QVL-300, QVL3-100,

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN60598-2-22:2015, EN60598-1:2011, EN62471:2009, EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2011, EN61000-3-2:2014 and EN61000-3-3:2013) and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012).

Whit the following technical characteristics:

Power	Class	IP	IK	Glow wire test
230V 50/60Hz	II	44	10	850

Signed and stamped:



Normagrup Technology S.A.  
Parque Tecnológico de Asturias, Parcela 10  
33129 Llanera (Asturias) España  
T +34 985 26 100 / F +34 985 26 101  
normagrup.com

**Mikel Jaureguizar**  
General Manager

**Normagrup Technology, S.A**  
Parque Tecnológico de Asturias  
Parcela 10  
33428 Llanera (Asturias)  
España / Spain  
normagrup.com