

**- Declaration of Conformity -**  
**CE Marking**

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A that the surface mounted emergency lights mentioned below comply with all related standards:

COMERCIAL BRAND: **ARQUE**  
References:

QS-S4L24, QV-S4L24, QSI-S4L24, QVI-S4L24

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN50171:2002, EN60598-1:2015, EN2471:2009, EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2011, EN61000-3-2:2014 and EN61000-3-3:2013) and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012).

Whit the following technical characteristics:

Alimentación	Clase	IP	IK	Hilo Incandescente
230V 50/60Hz	II	44	07	850

Signed and stamped:

**Normagrup Technology, S.A**  
Parque Tecnológico de Asturias  
Parcela 10  
33428 Llanera (Asturias)  
España / Spain  
[normagrup.com](http://normagrup.com)



Normagrup Technology, S.A.  
Parque Tecnológico de Asturias Parcela 10  
33428 Llanera (Asturias). España / Spain  
T. 985 266 992 / F. 985 266 992  
[normagrup.com](http://normagrup.com)

**Mikel Jaureguizar**  
**General Manager**