

# AENOR

ENEC Certification Body registered under ID # 01. For further information, please consult [www.enec.com](http://www.enec.com)

# LICENCE

to use the European Mark



**Licence Nr.** ENEC/001020

**Under the conditions given in the following pages of this document, the licence to use the ENEC Mark in conjunction with the suffix 01, as shown above, has been issued to:**

NORMAGRUP TECHNOLOGY, S.A.  
PQ TECNOLÓGICO ASTURIAS PARCELA 10  
33428 LLANERA (Asturias – España / Spain)

**For the product(s):**

LED luminaires for emergency lighting

**Trade name(s):**

NormaLux

**Complying with the following European Standards:**

EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022;  
EN IEC 60598-2-22:2022;  
EN 62262:2002; EN 62262:2002/A1:2021

**Date:** 2024-11-22

**Signature:**

A handwritten signature in blue ink, appearing to read 'Rafael García', with a long horizontal stroke extending to the right.

**Name:** Rafael García

**Position:** Chief Executive Officer

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

AENOR CONFÍA, S.A.U.  
Cl Génova, 6  
28004 MADRID (Spain)

## CERTIFICATE OF THE ENEC EUROPEAN MARK

Type of Product	LED LUMINAIRES FOR EMERGENCY LIGHTING
r1) Certificate n°	ENEC/001020
r2) Date of the Certificate	2024-11-22
r3) report n°	2024060435B1
r4) Name and address of the licensee	NORMAGRUP TECHNOLOGY, S.A. PQ TECNOLÓGICO ASTURIAS PARCELA 10 33428 LLANERA (Asturias - España / Spain)
r5) Address of the factory	PQ TECNOLÓGICO ASTURIAS - PARCELA, 10 33428 LLANERA (Asturias - España / Spain)
r6) European Standard	EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022; EN IEC 60598-2-22:2022; EN 62262:2002; EN 62262:2002/A1:2021
r7) Type reference	See above for details
r8) Trade Mark	NormaLux
r9) Rated voltage and frequency	230 V~; 50/60 Hz
r10) N° lamps x rated power, type and lampholder	See above for details
r11) IP degree of protection	IP 42; IK 04
r12) Power supply connection means	Bornes terminals
r13) Classif. per holding surface material	Apta para superficies normalmente inflamables Suitable for normally flammable surfaces
r14) Protection against electric shocks (class)	Clase Class II
r15) Rated lumen output and duration	See above for details
r16) Battery features	See above for details
r17) Additional information	See above for details
r18) General data	See above for details

Date of expiry: 2029-11-22

This certificate supersedes certificate 007/001020, dated 2021-11-19.

## CERTIFICATE OF THE ENEC EUROPEAN MARK

Type reference	Nº lamps x rated power, type and lampholder	Rated lumen output and duration	Battery features	Additional information	General data
Excellence EAL-250M-MH	25 x 0,5 W; LED	250 lm - emergencia emergency; 1 h	Ni-MH 4,8 V 850 mAh 4 elementos cells	Permanente Maintained; puesta en reposo a distancia remote rest	Protecciones: termistor PTC y fusible Protections: PTC thermistor and fuse
Excellence EAL-250M	25 x 0,5 W; LED	250 lm - emergencia emergency; 1 h	Ni-Cd 4,8 V 750 mAh 4 elementos cells	Permanente Maintained; puesta en reposo a distancia remote rest	Protecciones: termistor PTC y fusible Protections: PTC thermistor and fuse
Excellence EAL-300M	25 x 0,5 W; LED	330 lm - emergencia emergency; 1 h	Ni-Cd 6 V 750 mAh 5 elementos cells	Permanente Maintained; puesta en reposo a distancia remote rest	Protecciones: termistor PTC y fusible Protections: PTC thermistor and fuse
Excellence E-S24L	24 x 0,5 W; LED	320 lm - permanencia permanence; para alimentación central for central supply	Sin batería without battery	Permanente Maintained	Protecciones: termistor PTC Protections: PTC thermistor