

- Declaration of Conformity -

CE Mark

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A. that the escape route lighting devices mentioned below and their pictograms, if included, comply with all related standards.

COMMERCIAL BRAND: **EXTRALINE**

References:

XD, XD3, XD3T, XDA, XDA3, XDID3-R, XDID-R, XDT, XS, XS3, XS-4, XSA, XSA3, XSA3Li, XSA-MH, XSDA, XSDA-MH, XSID3-R, XSID-R, XSID-D-L-I, XSID-D-R-I, XSID-D-SU-I

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN IEC 60598-2-22:2022, EN IEC 60598-1:2021, EN62471:2008 and EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2009, EN61000-3-2:2014 and EN61000-3-3:2013), and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012). As well as the requirements set by the EN 1838:2013 regarding Lighting applications (Emergency lighting).

With the following technical characteristics:

Power	Class	IP	IK	Glow wire test
230V 50/60Hz	II	20	07	850