

**- Declaration of Conformity -**

CE Mark

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A. that the surface mounted emergency lights for central battery system mentioned below comply with all related standards.

COMMERCIAL BRAND: **EXTRAPLANA**

References:

FI-S32L24, F-S32L24

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN50171:2001, EN60598-1:2015, EN62471:2008 and EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2009, EN61000-3-2:2014 and EN61000-3-3:2013), and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012).

With the following technical characteristics::

Power	Class	IP	IK	Glow wire test
24 Vdc	III	44	04	850

Signed and stamped:

 **Normagrup**

Normagrup Technology, S.A.  
Parque Tecnológico de Asturias - Parcela 10  
33428 Llanera (Asturias) - España / Spain  
T. 985 267 100 / F. 985 266 922  
[normagrup.com](http://normagrup.com)

  
**Mikel Jaureguizar**  
General Manager