

AENOR

ENEC Certification Body registered under ID # 01. For further information, please consult www.enec.com

LICENCE

to use the European Mark



Licence Nr. ENEC/001220

Under the conditions given in the following pages of this document, the licence to use the ENEC Mark in conjunction with the suffix 01, as shown above, has been issued to:

NORMAGRUP TECHNOLOGY, S.A.
Parque TECNOLÓGICO ASTURIAS
33428 LLANERA (Asturias – España / Spain)

For the product(s):

LED luminaires for emergency lighting

Trade name(s):

NormaLux

Complying with the following European Standards:

EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022;
EN IEC 60598-2-22:2022;
EN 62262:2002; EN 62262:2002/A1:2021

Date: 2025-06-30

Signature:

A handwritten signature in blue ink, appearing to read 'Rafael García', with a stylized flourish at the end.

Name: Rafael García

Position: Chief Executive Officer

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

AENOR CONFÍA, S.A.U.
Cl Génova, 6
28004 MADRID (Spain)

CERTIFICATE OF THE ENEC EUROPEAN MARK

Type of Product	LED LUMINAIRES FOR EMERGENCY LIGHTING
r1) Certificate n°	ENEC/001220
r2) Date of the Certificate	2025-06-30
r3) report n°	2025020216B1
r4) Name and address of the licensee	NORMAGRUP TECHNOLOGY, S.A. Parque TECNOLÓGICO ASTURIAS 33428 LLANERA (Asturias - España / Spain)
r5) Address of the factory	PQ TECNOLÓGICO ASTURIAS - PARCELA, 10 33428 LLANERA (Asturias - España / Spain)
r6) European Standard	EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022; EN IEC 60598-2-22:2022; EN 62262:2002; EN 62262:2002/A1:2021
r7) Type reference	See above for details
r8) Trade Mark	NormaLux
r9) Rated voltage and frequency	230V~ 50/60 Hz
r10) N° lamps x rated power, type and lampholder	18 x 0,5 W; LED
r11) IP degree of protection	IP20; IK04
r12) Power supply connection means	Terminals
r13) Classif. per holding surface material	Suitable for normally flammable surfaces
r14) Protection against electric shocks (class)	Class II
r15) Rated lumen output and duration	See above for details
r16) Battery features	See above for details
r17) Additional information	See above for details
r18) General data	See above for details
Date of expiry: 2029-06-30	This certificate supersedes certificate 007/001220, dated 2023-01-16.

CERTIFICATE OF THE ENEC EUROPEAN MARK

Type reference	Rated lumen output and duration	Battery features	Additional information	General data
SGA-MH-K	85 lm (emergency); 1 h	Ni-MH 3 cell 3,6V 850 mAh	Maintained	Signal Series; fuse, PTC and varistor protection
SGE-K	100 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Non-maintained	Signal Series; fuse protection
SG-K	85 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained	Signal Series; fuse, PTC and varistor protection
SG-MH-K	85 lm (emergency); 1 h	Ni-MH 3 cell 3,6V 850 mAh	Maintained	Signal Series; fuse, PTC and varistor protection