

- Declaration of Conformity -

CE Mark

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A. that the escape route lighting devices mentioned below and their pictograms, if included, comply with all related standards.

COMMERCIAL BRAND: **SIGNAL**

References:

SG3-K, SG3-K-1, SG3-K-2, SGA3-K, SGA3-K-1, SGA3-K-2, SGA-K, SGA-K-1, SGA-K-2, SGEA3-K, SGEA3-K-1, SGEA3-K-2, SGEA-K, SGEA-K-1, SGEA-K-2, SGEID3-K, SGEID3-K-1, SGEID3-K-2, SGID3-K, SGID3-K-1, SGID3-K-2, SGID-K, SGID-K-1, SGID-K-2, SG-K, SG-K-1, SG-K-2

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN60598-2-22:2014, EN60598-1:2015, EN62471:2008 and EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2009, EN61000-3-2:2014 and EN61000-3-3:2013), and **Restriction of the use of certain hazardous substances (Rohs)** 2011/65/EU (standard EN50581:2012). As well as the requirements set by the EN 1838:2013 regarding Lighting applications (Emergency lighting).

With the following technical characteristics::

Power	Class	IP	IK	Glow wire test
230V 50/60Hz	II	20	04	850

Signed and stamped:


Normagrup

Normagrup Technology, S.A.
 Parque Tecnológico de Asturias. Parcela 10
 33428 Llanera (Asturias). España / Spain
 T. 985 267 100 / F. 985 266 992
 normagrup.com


Mikel Jaureguizar
 General Manager