

## - Declaration of Conformity -

CE Mark

MIKEL JAUREGUIZAR DE ZÁRATE declares:

As General Manager of the company Normagrup Technology S.A. that the recessed emergency lights mentioned below comply with all related standards.

COMMERCIAL BRAND: **VÍA LED**

References:

VS, VS3, VS-4, VSA, VSA3, VSA-4, VSE, VSE-1, VSE3, VSE-4, VSEA, VSEA3, VSEA-4, VSEAH, VSEAH-4, VSEH, VSEH-1, VSEH-4, VSEID, VSEID3, VSEIDH, VSID, VSID3, VSID-4, VV, VV3, VV3-4, VV-4, VVA, VVA3, VVA3-4, VVA-4, VVE, VVE-1, VVE3, VVEA, VVEA3, VVEA-4, VVEAH, VVEAH-4, VVEH, VVEH-4, VVEID, VVEID3, VVEIDH, VVID, VVID3, VVID3-4, VVID-4

Meet the requirements of the **Low Voltage Directive of the European 2014/35/UE** (standards EN60598-2-22:2014, EN60598-2-2:2012, EN60598-1:2015, EN62471:2008 and EN62493:2015). Equally they meet the requirements of the **Electromagnetic Compatibility Directive (EMC)**, 2014/30/UE (standards EN55015:2013, EN61547:2009, EN61000-3-2:2014 and EN61000-3-3:2013), and **Restriction of the use of certain hazardous substances (RoHS) 2011/65/EU** (standard EN50581:2012).

With the following technical characteristics::

Power	Class	IP	IK	Glow wire test
230V 50/60Hz	II	20	04	850

 **Normagrup**  
Signed and stamped:

Normagrup Technology, S.A.  
Parque Tecnológico de Asturias. Parcela 10  
33428 Llanera (Asturias). España / Spain  
T. 985 267 100 / F. 985 266 982  
normagrup.com

  
Mikel Jaureguizar  
General Manager