

AENOR

ENEC Certification Body registered under ID # 01. For further information, please consult www.enec.com

LICENCE

to use the European Mark



Licence Nr. ENEC/001247

Under the conditions given in the following pages of this document, the licence to use the ENEC Mark in conjunction with the suffix 01, as shown above, has been issued to:

NORMAGRUP TECHNOLOGY, S.A.
Parque TECNOLÓGICO ASTURIAS
33428 LLANERA (Asturias - España)

For the product(s):

LED luminaires for emergency lighting

Trade name(s):

Normalux

Complying with the following European Standards:

EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022;
EN IEC 60598-2-22:2022;
EN 62262:2002; EN 62262:2002/A1:2021

Date: 2026-06-24

Signature:

A handwritten signature in blue ink, appearing to read 'Rafael García'.

Name: Rafael García
Position: Chief Executive Officer

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

AENOR CONFÍA, S.A.U.
Cl Génova, 6
28004 MADRID (Spain)

CERTIFICATE OF THE ENEC EUROPEAN MARK

Type of Product	LED LUMINAIRES FOR EMERGENCY LIGHTING
r1) Certificate n°	ENEC/001247
r2) Date of the Certificate	2026-06-24
r3) report n°	2025020214B1-1-M1
r4) Name and address of the licensee	NORMAGRUP TECHNOLOGY, S.A. Parque TECNOLÓGICO ASTURIAS 33428 LLANERA (Asturias - Spain)
r5) Address of the factory	PQ TECNOLÓGICO ASTURIAS - PARCELA 10 33428 LLANERA (Asturias - Spain)
r6) European Standard	EN IEC 60598-1:2021; EN IEC 60598-1:2021/A11:2022; EN IEC 60598-2-22:2022; EN 62262:2002; EN 62262:2002/A1:2021
r7) Type reference	See above for details
r8) Trade Mark	NormaLux
r9) Rated voltage and frequency	230V~ 50/60 Hz
r10) N° lamps x rated power, type and lampholder	See above for details
r11) IP degree of protection	IP40; IK04
r12) Power supply connection means	See above for details
r13) Classif. per holding surface material	Suitable for normally flammable surfaces
r14) Protection against electric shocks (class)	Class II
r15) Rated lumen output and duration	See above for details
r16) Battery features	See above for details
r17) Additional information	See above for details
r18) General data	See above for details

Date of expiry: 2029-04-30

This certificate supersedes certificate 007/001247, dated 2026-01-13.

CERTIFICATE OF THE ENEC EUROPEAN MARK

Type reference	N° lamps x rated power, type and lampholder	Power supply connection means	Rated lumen output and duration	Battery features	Additional information	General data
VMSALi	2 x 3 W; LED	Terminals	250 lm (emergency); 1 h	Li 3,2 V 1,5 Ah	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMSA	2 x 3 W; LED	Terminals	210 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse, PTC and varistor protection; ta = 40 °C
VMSEA	4 x 0,5 W; LED	Terminals	195 lm (emergency); 1h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMSE	4 x 0,5 W; LED	Terminals	195 lm; 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Non-maintained	Vía S Series; fuse protection; ta = 40 °C
VMSE3	4 x 0,5 W; LED	Terminals	185 lm; 3 h	Ni-Cd 3 cell 3,6 V 1,5 Ah	Non-maintained	Vía S Series; fuse protection; ta = 40 °C
VMSIDLi	2 x 3 W; LED	Terminals	260 lm (emergency); 1 h	Li 3,2 V 1,5 Ah	Maintained (possible non-maintained); DALI	Vía S Series; fuse protection; ta = 40 °C
VMSID	2 x 3 W; LED	Terminals	210 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); DALI	Vía S Series; remote rest; fuse, PTC and varistor protection; ta = 40 °C
VMVALi	2 x 3 W; LED	Terminals	260 lm (emergency); 1 h	Li 3,2 V 1,5 Ah	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMVA-MH	2 x 3 W; LED	Terminals	220 lm (emergency); 1 h	Ni-MH 3 cell 3,6 V 850 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMVA	2 x 3 W; LED	Terminals	220 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse, PTC and varistor protection; ta = 40 °C

AENOR CONFÍA S.A.U.

Génova, 6. 28004 Madrid. Spain

Tel. +34 91 432 60 00.-

www.aenor.com

Product certification body accredited by ENAC, number 1/C-PR275

CERTIFICATE OF THE ENEC EUROPEAN MARK

Type reference	N° lamps x rated power, type and lampholder	Power supply connection means	Rated lumen output and duration	Battery features	Additional information	General data
VMVEAH-MH	2 x 3 W; LED	Terminals	415 lm (emergency); 1h	Ni-MH 3 cell 3,6 V 1,5 Ah	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMVEA-MH	4 x 0,5 W; LED	Terminals	195 lm (emergency); 1h	Ni-MH 3 cell 3,6 V 850 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMVEA	4 x 0,5 W; LED	Terminals	195 lm (emergency); 1h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse protection; ta = 40 °C
VMVE	4 x 0,5 W; LED	Terminals	195 lm; 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Non-maintained	Vía S Series; fuse protection; ta = 40 °C
VMVE3	4 x 0,5 W; LED	Terminals	180 lm; 3 h	Ni-Cd 3 cell 3,6 V 1,5 Ah	Non-maintained	Vía S Series; fuse protection; ta = 40 °C
VMVIDLi	2 x 3 W; LED	Terminals	265 lm (emergency); 1 h	Li 3,2 V 1,5 Ah	Maintained (possible non-maintained); DALI	Vía S Series; fuse protection; ta = 40 °C
VMVID	2 x 3 W; LED	Terminals	220 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); DALI	Vía S Series; remote rest; fuse, PTC and varistor protection; ta = 40 °C
VTVA	2 x 3 W; LED	Track adaptor	220 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse, PTC and varistor protection; ta = 40 °C
VTVA-4	2 x 3 W; LED	Track adaptor	220 lm (emergency); 1 h	Ni-Cd 3 cell 3,6 V 750 mAh	Maintained (possible non-maintained); Autotest	Vía S Series; fuse, PTC and varistor protection; ta = 40 °C